



Access Plan Worksheet Example 2

Location: Gallery 5

Institutional Priority (circle one)

ADAAG: Horizontal Circulation # 4.3

Immediate

Short-Term (<6 months)

Long Term

Barriers to address	Steps to reach solutions	Staff & others responsible	Budgetary considerations	Start date	Expected completion date
	Resources used for this plan: <i>ADA Accessibility Guidelines for Buildings & Facilities</i> , 4.3 "Accessible Route" and 4.4 "Protruding Objects;" <i>Smithsonian Guidelines for Accessible Exhibitions</i> , pp. 41-46; <i>Everyone's Welcome</i> , pp. 60-69.	S. Simon, manager of exhibits I. Newton, head of operations	Staff time: 2 hours research 2 hours moving furniture	May 2000	June 2000
Too narrow in 3 spots for a person with a mobility limitation to pass	Move furniture to widen route or create an alternate route that still provides access to all exhibits to circumvent tight spots.				
Two dead ends without sufficient maneuvering clearance to turn	Move furniture to open up dead ends, widen space to allow a five-foot turning diameter, or provide an alternative experience to the exhibits that are inaccessible.				
Four protruding objects not cane-detectable (higher than 27 inches above floor)	Move the protruding objects away from the circulation route, or place cane-detectable barriers under the protrusions.				